

رضا

## All-in-one Test Solution

# KAVOSH T22



All-in-one Test Solution

# KAVOSH T22



## Power Transformer Diagnostics

---



## International Standards related to PT

### Standards

- IEC 60076
- IEEE C57.152
- IEC 61378-1
- IEC 60137
- IEC 60214
- IEEE C12.90
- IEEE C57.125
- IEC 60422
- IEEE C57.104



IEC 60076-1

Edition 3.0 2011-04

**INTERNATIONAL  
STANDARD**

**NORME  
INTERNATIONALE**

Power transformers –  
Part 1: General

IEEE STANDARDS ASSOCIATION



**IEEE Guide for Diagnostic Field  
Testing of Fluid-Filled Power  
Transformers, Regulators, and  
Reactors**

IEEE Power and Energy Society

Sponsored by the  
Transformers Committee

IEEE  
3 Park Avenue  
New York, NY 10016-5997  
USA


IEEE Std C57.152™-2013  
(Revision of  
IEEE Std 62™-1995)

## On-site Tests of the **PT**

---

- Winding Resistance
- Dynamic Resistance of On Load Tap Changers (OLTCs)
- Demagnetization
- Turn Ratio (TTR)
- Excitation Current (No-Load Current)
- Magnetic Balance
- Vector Group
- Short Circuit Impedance
- Zero Sequence Impedance
- Capacitance and Dissipation Factor
- Insulation Resistance

## On-site Tests of the PT



## On-site Tests of the PT

### Dynamic resistance of On Load Tap changers (OLTCs)






Figure 1. Failure location of substation transformers based on 536 failures [1]



## On-site Tests of the PT

### Dynamic resistance of On Load Tap changers (OLTCs)



## On-site Tests of the PT

### Resistive Oil Type OLTC




Fig. 11: Design principle – diverter switch (arcing switch) with tap selector OILTAP® M®




Fig. 13: Design principle – selector switch (arcing tap switch) OILTAP® V®

## On-site Tests of the PT

### Resistive Oil Type OLTC




Fig. 14: Switching sequence of selector switch (arcing tap switch) OILTAP® V®




Fig. 12: Switching sequence of tap selector - diverter switch (arcing switch)

## On-site Tests of the PT






Figure 2.1 Selector switch type OLTC with of the stator contacts of a selector switch wh

Figure 2.2 Diverter switch with transition resistors (top) and a tap selector (bottom).

picture  
!

# On-site Tests of

## Resistive Oil Type OLTC







Fig. 3.8 a-f Page 1: Interruption duties of diverter switch. g-n Page 2: Interruption duties of diverter switch. o-u Page 3: Interruption duties of diverter switch. v-ac Page 4: Interruption duties of diverter switch



**Four Resistance Diverter Switch Switching Sequence**

## On-site Tests of the PT

### Four Resistance Diverter Switch Switching Sequence






fig. 3.13 Operating sequence of four resistance diverter switch



- MTS** Tap selector contacts, main path
- MSV** Main switching contacts (vacuum interrupter), main path
- TTS** Tap selector contacts, transition path
- TTV** Transition contacts (vacuum interrupter), transition path
- STC** Sliding take-off contacts
- R** Transition resistor
- IC** Circulating current
- m, m+1** Tap m, tap m+1

Fig. 28: Switching sequence of resistor type OLTC with the same vacuum interrupters for the closing and opening side of the diverter switch – VACUTAP® VV®






- MSV** Main switching contacts (vacuum interrupter), main path
- MTF** Transfer switch, main path
- TTV** Transition contacts (vacuum interrupter), transition path
- TTF** Transfer switch, transition path
- MCA** Main contacts side A
- MCB** Main contacts side B
- ZNO** ZNO arrester
- R** Transition resistor

Fig. 29: Switching sequence of resistor type OLTC VACUTAP® VR®

## On-site Tests of the PT

### Tie-in Resistor



## On-site Tests of the PT

---

### Dynamic resistance vs static resistance

#### ➤ **Static winding resistance measurement:**

Investigation of resistance-oriented issues of winding, bushing connection and contact, and tap changer connection and contacts

#### ➤ **Dynamic resistance measurement (DRM) of OLTC:**

Investigation of transient contacts, transition resistor/reactor, and OLTC mechanism during tap switching intervals (between 40 to 70 ms)

## On-site Tests of the **PT**

---

### Measurement methods:

- Discontinuity detection
  - Dynamic current (resistance) measurement
- 
- A solid dark blue rectangular block is located in the bottom left corner of the slide.

## On-site Tests of the PT

---

### Measurement methods:

#### ➤ Discontinuity detection:

- ✓ Detecting undesired break before make condition by monitoring current change
- ✓ Simultaneous winding resistance measurement

This test starts after severe core saturation. This results in more current level change and longer duration.

## On-site Tests of the PT

---

### Measurement methods:

#### ➤ Dynamic Current Measurement:

- ✓ Describes conditions during operation and provide contact timing
- ✓ Detect discontinuity with current change detection
- ✓ Presented as a percentage ripple, slope, and current-time diagram

## On-site Tests of the PT

---

### Measurement principle




#### ➤ Discontinuity detection:

- ✓ Detecting undesired break before make condition by monitoring current change
- ✓ Simultaneous winding resistance measurement

This test starts after severe core saturation. This results in more current level change and longer duration.

## On-site Tests of the PT

### Measurement principle







## On-site Tests of the PT

### Measurement principle

- Not measured directly, calculated from measured voltage and current


$$U = RW \times I + \left(\frac{n_1}{n_2}\right) \times U_2 + U_{OLTC}$$

$$R_{OLTC} = \frac{U_{OLTC}}{I}$$




## On-site Tests of the PT

### Measurement principle



## On-site Tests of the PT


### Measurement principle




## On-site Tests of the PT

### Secondary Short Circuit:

Dynamic OLTC-scan (DRM)




Dynamic OLTC-scan (DRM)






## On-site Tests of the PT

### Secondary Short Circuit:

- Open LV




- Shorted LV




## On-site Tests of the PT

### I Test ?



*Figure 4.8 Static resistance measurements of service-aged OLTC contacts. The measurement current was increased to 100 A. A strong dependency of the contact resistance on the measurement current is revealed.*

Static resistance of new and degraded contacts





*Figure 4.9 The contact resistance of clean and degraded contacts when the current is increased from 2.5 A to 100 A. Degraded contacts show high resistances at low currents, while the difference between clean and degraded contacts becomes smaller at higher currents.*

## On-site Tests of the PT

### I Test ?




- Same transition time for both currents
- Lower current more sensitive to contact bouncing
- Oil coating – Can cause false interruption
- Max 15 % of rated current.



## On-site Tests of the PT

Ripple and Slope:





## On-site Tests of the PT

---

### Ripple and Slope:

#### Slope:

- reflects the resistivity of the current carrying transition components.
- If current decays more rapidly than expected, this indicates that the transition path has become more resistive than normal.


#### Ripple:

- If the ripple is uncharacteristically large, this indicates an increase in the resistance of the transition path *and/or* that the tap change operation is slower than it should be.

## On-site Tests of the PT

### OLTC DRM (Dynamic Resistance Measurement)

30MVA, 63/20kV, MR- VV,




□	↑ ↓	Phase	Tap	Ripple	Slope
<input type="checkbox"/>	↓	A	17 to 16	40.65 %	87.42 A/s
<input type="checkbox"/>	↓	A	18 to 17	40.49 %	84.77 A/s
<input type="checkbox"/>	↓	A	19 to 18	40.50 %	81.72 A/s
<input type="checkbox"/>	↑	A	16 to 17	39.83 %	83.35 A/s
<input type="checkbox"/>	↑	A	17 to 18	39.58 %	80.61 A/s
<input type="checkbox"/>	↑	A	18 to 19	39.34 %	77.19 A/s

## On-site Tests of the PT

### OLTC DRM (Dynamic Resistance Measurement)


50MVA, 132/34 kV, Dyn1, MR- VV,



## On-site Tests of the PT

### OLTC DRM (Dynamic Resistance Measurement)

22.5MVA, 63/20kV, ABB-UBB,





Tap	Phase	Tap	Ripple	Slope	
□	↓	A	2 to 1	41.00 %	159.76 A/s
□	↓	A	3 to 2	42.45 %	188.82 A/s
□	↓	A	4 to 3	37.24 %	124.56 A/s
□	↓	A	5 to 4	41.42 %	165.69 A/s
□	↓	A	6 to 5	40.11 %	148.4 A/s
□	↓	A	7 to 6	36.44 %	114.05 A/s
□	↓	A	8 to 7	41.96 %	179.27 A/s
□	↓	A	9 to 8	43.13 %	192.82 A/s
□	↓	A	10 to 9	38.59 %	132.9 A/s
□	↓	A	11 to 10	37.81 %	127.14 A/s
□	↓	A	12 to 11	43.80 %	188.96 A/s
□	↓	A	13 to 12	42.23 %	171.87 A/s
□	↓	A	14 to 13	40.37 %	143.91 A/s
□	↓	A	15 to 14	34.99 %	108.82 A/s
□	↓	A	16 to 15	39.35 %	140.1 A/s
□	↓	A	17 to 16	40.87 %	153.04 A/s
□	↓	A	18 to 17	36.70 %	116.86 A/s
□	↓	A	19 to 18	37.56 %	122.33 A/s

## On-site Tests of the PT

### OLTC DRM (Dynamic Resistance Measurement)


410MVA, 420/20kV, MR VMIII,



## On-site Tests of the PT

### OLTC DRM (Dynamic Resistance Measurement)

312.5MVA, 230/19 kV, Mitsubishi, MR (Mofatteh, Hamedan)



## On-site Tests of the PT

### OLTC DRM (Dynamic Resistance Measurement)

#### On load reactor type tap changer




Figure 1.  
Dynamic graph of a resistor tap changer  
fine-coarse regulation





Figure 2.  
Dynamic graph of a reactor tap changer  
plus-minus regulation

## On-site Tests of the PT

### OLTC DRM (Dynamic Resistance Measurement)

Case1:





## On-site Tests of the PT

### OLTC DRM (Dynamic Resistance Measurement)

Case7:




Figure 8.  
Transition Time in Excess of 1 Second

## On-site Tests of the PT

### OLTC DRM (Dynamic Resistance Measurement)

#### Case8:




Figure 9.

The Second Resistor Does Not Make, Creating an Open Circuit

## On-site Tests of the PT

### OLTC DRM (Dynamic Resistance Measurement)

Case9:




Figure 23.

Abnormal Transition Showing Incorrect Bypass Switch Operation








Figure 24.

Normal Transition of This Type of Tap Changer

## On-site Tests of the PT

### DRM Analysis

- ✓ Comparing to a finger print measurement
- ✓ Phase-to-phase comparison
- ✓ Switching time and interruptions



## On-site Tests of the PT

DRM: **KAVOSH T22**

Device Specification **Configuration** Signal View Results

Configurations ? i A

Vector Group:	<span>N</span> D	d
Phase:	U	
I Test *:	A	
Test Mode:	Manual	
Start Tap:	1	
Tap Changer Direction:	Up	
Oil Temperature:	°C	

## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

#### How?

- De-energize and isolate transformer.
- Transformer tank and bushing flange should be grounded properly.
- All terminals with neutral for the same winding must be connected together.




## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

How?

2-winding transformer



## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

How?

2-winding transformer

Test Object:

Transformer


Transformer Type:

2 Winding

Target Capacitor:

CHL

• Measuring Mode: UST\_A





## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

How?

2-winding transformer

Test Object:

Transformer


Transformer Type:

2 Winding

Target Capacitor:

CHG

• Measuring Mode: GSTg\_AB



## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

How?

2-winding transformer

Test Object:

Transformer


Transformer Type:

2 Winding

Target Capacitor:

CHG + CHL

• Measuring Mode: GSTg\_B



## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

How?

2-winding transformer

Test Object:

Transformer


Transformer Type:

2 Winding

Target Capacitor:

CLG

• Measuring Mode: GSTg\_AB



## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

How?

2-winding transformer

Test Object:

Transformer


Transformer Type:

2 Winding

Target Capacitor:

CLH

• Measuring Mode: UST\_A



## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

How?

2-winding transformer

Test Object:

Transformer


Transformer Type:

2 Winding

Target Capacitor:

CLG + CLH

Measuring Mode: GSTg\_B




## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

How?

3-winding transformer



## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

How?

3-winding transformer

Test Object:


Transformer

Transformer Type:

3 Winding

Target Capacitor:

CHG



## On-site Tests of the PT


### Capacitance and Dissipation Factor Measurement (TDM1)

How?

3-winding transformer

- CHG
- CHL
- CHT
- CHL + CHG
- CLG
- CLH
- CLT
- CLT + CLG
- CTG
- CTH
- CTL
- CTH + CTG
- CTH + CTL
- CTL + CTG
- CTH + CTL + CTG
- CLH + CLT
- CLH + CLT + CLG
- CLH + CLG
- CHL + CHT
- CHT + CHG

More wirings available on: [kavosh.online](http://kavosh.online)






## On-site Tests of the PT


### Capacitance and Dissipation Factor Measurement (TDM1)

How?

Autotransformer



)




## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

How?

Autotransformer without tertiary winding (inaccessible)


GST



## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

How?  
Reactor  
GST



## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

230kV/14.4kV, 160MVA

Point	Mode	Frequency	V out	I out	Cap	DF	T Oil
CL+CLH	GST	55 Hz	1.9988 kV	27.913 mA	40.369 nF	0.641	10 °C
CL	GSTg_A	55 Hz	1.9984 kV	21.064 mA	30.491 nF	0.667	10 °C
CLH	UST_A	55 Hz	9.9958 kV	34.196 mA	9899.6 pF	0.586	10 °C
CLH	UST_A	55 Hz	1.998 kV	6.8421 mA	9909.4 pF	0.615	10 °C
CH+CHL	GST	55 Hz	9.991 kV	66.974 mA	19.452 nF	0.597	10 °C
CH+CHL	GST	55 Hz	1.9992 kV	13.421 mA	19.42 nF	0.603	10 °C
CH	GSTg_A	55 Hz	9.9956 kV	32.85 mA	9503.3 pF	0.616	10 °C
CH	GSTg_A	55 Hz	2.0012 kV	6.5785 mA	9515 pF	0.618	10 °C
CHL	UST_A	55 Hz	9.9986 kV	34.171 mA	9894.7 pF	0.611	10 °C
CHL	UST_A	55 Hz	1.9979 kV	6.8486 mA	9909.8 pF	0.616	10 °C
CL+CLH	GST	55 Hz	9.9999 kV	139.81 mA	40.385 nF	0.648	10 °C
CL	GSTg_A	55 Hz	10.001 kV	105.67 mA	30.513 nF	0.670	10 °C

## On-site Tests of the PT

### Capacitance and Dissipation Factor Measurement (TDM1)

#### Assessment:

✓ IEEE C57.152  
Limits for DF @ 20°C

Insulation	Voltage Level	Maximum DF for new PT	Maximum DF for old PT
Mineral Oil	< 230 kV	0.5 %	1 %
Mineral Oil	>= 230kV	0.4 %	1 %
Natural Ester	All	1 %	1 %

#### Limits for C


$\Delta C$	Voltage Level
< 5 %	Acceptable
< 5 % $\Delta C$ < 10 %	Should be investigated
> 10 %	Critical

## On-site Tests of the **PT**

---

### Capacitance and Dissipation Factor Measurement (**TDM1**)

#### **Assessment:**

- Tan delta rate of change is an important index indicating ageing rate or main insulation damage
  - Analysis can be done by comparing results of various bushings, comparing results with similar assets and previous tests, and rate of change
  - Complementary tests may be required to verify the quality of the insulation fluid (oil dielectric tests and dissolved gas analysis)
  - Shorter test interval may be required for higher tan delta rate of change
- 
- A solid dark blue rectangular block is located in the bottom left corner of the slide.

## On-site Tests of the PT

---

### Capacitance and Dissipation Factor Measurement (TDM1)

#### Acceptance Criteria

- ✓ Measuring of bushing and transformer tan delta on an equalized temperature (oil and winding) and preferably at the same temperature of previous tests
- ✓ Comparing the absolute value of tan delta with the acceptable one (between 2 times of the initial value and 1%)
- ✓ Comparing the rate of change of tan delta with the acceptable value
  - ✓ One year : 0.05%
  - ✓ Two years: 0.07%
  - ✓ Three years: 0.09%
  - ✓ Four years: 0.11%

## On-site Tests of the PT

DF: KAVOSH T22

Device Specification

Configuration

Signal View

Results

Configurations



Test Object:

Transformer

Transformer Type:

2 Winding

Target Capacitor:

CHL

• Measuring Mode: UST\_A

Test Mode:

Manual

Reference Capacitor:

Internal

V Test \*:

V

Frequency:

52.5 Hz

No. of Avg. Points:

5


T Oil:

20

°C

• Correction Factor: 1



**E**  **F** **A**

**ESFAGroup.com**